

GENEROSITYTM WATER

WATER QUALITY REPORT

750 Royal Oaks Drive, Suite 100
 Monrovia, California 91016-3629
 Tel: (626) 386-1100
 Fax: (626) 386-1101
 1 800 566 LABS (1 800 566 5227)



STATE CERTIFICATION LIST

State	Certification Number	State	Certification Number
Alabama	41060	Mississippi	Certified
Alaska	CA00006	Montana	Cert 0035
Arizona	AZ0778	Nebraska	Certified
Arkansas	Certified	Nevada	CA00006-2014-1
California-Monrovia-ELAP	2813	New Hampshire *	2959
California-Colton- ELAP	2812	New Jersey *	CA 008
California-Folsom- ELAP	2820	New Mexico	Certified
Colorado	Certified	New York *	11320
Connecticut	PH-0107	North Carolina	06701
Delaware	CA 006	North Dakota	R-009
Florida *	E871024	Oregon (Primary AB) *	ORELAP 4034
Georgia	947	Pennsylvania *	68-565
Guam	14-003r	Rhode Island	LAO00326
Hawaii	Certified	South Carolina	87016
Idaho	Certified	South Dakota	Certified
Illinois *	200033	Tennessee	TN02839
Indiana	C-CA-01	Texas *	T104704230-14-6
Kansas *	E-10268	Utah *	CA000062014-7
Kentucky	90107	Vermont	VT0114
Louisiana *	LA140009	Virginia *	460260
Maine	CA0006	Washington	C838
Maryland	224	West Virginia	9943 C
Commonwealth of Northern Marianas Is.	MP0004	Wisconsin	998316660
Massachusetts	M-CA006	Wyoming	8TMS-L
Michigan	9906	EPA Region 5	Certified
Los Angeles County Sanitation Districts	10264		

* NELAP/TNI Recognized Accreditation Bodies

Laboratory Report

for

Generosity Beverages Inc.
 12800 Riverside Dr. Suite 200
 Valley Village, CA 91607
 Attn: Micah Cravalho

Date of Issue
 07/07/2014

Andrew Eaton
EUROFINS EATON
ANALYTICAL

ADE: Andrew.D.Eaton
 Project Manager

Report: 484133
 Project: BW
 Group: FDA Product
 PO#: Prepay

* Accredited in accordance with TNI 2009 and ISO/IEC 17025:2005.
 * Laboratory certifies that the test results meet all **TNI 2009 and ISO/IEC 17025:2005** requirements unless noted under the individual analysis.
 * Following the cover page are State Certification List, ISO 17025 Accredited Method List, Acknowledgement of Samples Received, Comments, Hits Report, Data Report, QC Summary, QC Report and Regulatory Forms, as applicable.
 * Test results relate only to the sample(s) tested.

Acknowledgement of Samples Received

The tests listed below are accredited and meet the requirements of ISO 17025 as verified by the ANSI-ASQ National Accreditation Board/ACCLASS. Refer to Certificate and scope of accreditation (AT 1807) found at: <http://www.eatonanalytical.com>

Addr: **Alkapuro inc**
7125 Telegraph Rd
Montebello, CA 90640

Client ID: ALKAPURO
Folder #: 484133
Project: BW
Sample Group: FDA Product

Attn: Randy Park
Phone: 714-883-9115

Project Manager: Andrew.D.Eaton
Phone: (626) 386-1125
PO #: Prepay

SPECIFIC TESTS	METHOD OR TECHNIQUE USED	Drinking Water	Food & Beverage	Waste Water
1,4-Dioxane	EPA 522	x	x	
2,3,7,8-TCDD	Modified EPA 1613B	x	x	
Acrylamide	In House Method	x	x	
Alkalinity	SM 2320B	x	x	x
Ammonia	EPA 350.1		x	x
Ammonia	SM 4500-NH3 H (18th)		x	x
Anions and DBPs by IC	EPA 300.0	x	x	x
Anions and DBPs by IC	EPA 300.1	x	x	
Asbestos	EPA 100.2	x		
Bicarbonate Alkalinity as HCO3	SM 2330B	x	x	x
BOD / CBOD	SM 5210B		x	x
Bromate	In House Method	x	x	
Carbamates	EPA 531.2	x	x	
Carbonate as CO3	SM 2330B	x	x	x
Carbonyls	EPA 556	x	x	
COD	EPA 410.4 / SM 5220D			x
Chloramines	SM 4500-CL G	x	x	x
Chlorinated Acids	EPA 515.4	x	x	
Chlorinated Acids	EPA 555	x	x	
Chlorine Dioxide	SM 4500-CLO2 D	x	x	
Chlorine -Total/Free/Combined Residual	SM 4500-CI G	x	x	x
Conductivity	EPA 120.1			x
Conductivity	SM 2510B	x	x	x
Corrosivity (Langelier Index)	SM 2330B	x	x	
Cyanide, Amenable	SM 4500-CN G	x		x
Cyanide, Free	SM 4500CN F	x	x	x
Cyanide, Total	EPA 335.4	x	x	x
Cyanogen Chloride (screen)	In House Method	x	x	
Diquat and Paraquat	EPA 549.2	x	x	
DBP/HAA	SM 6251B	x	x	
Dissolved Oxygen	SM 4500-O G		x	x
E. Coli	(MTF/EC+MUG)	x		
E. Coli	CFR 141.21(f)(6)(i)		x	x
E. Coli	SM 9223			x
E. Coli (Enumeration)	SM 9221B.1/ SM 9221F	x	x	
E. Coli (Enumeration)	SM 9223B	x	x	
EDB/DCBP	EPA 504.1	x		
EDB/DCBP and DBP	EPA 551.1	x	x	
EDTA and NTA	In House Method	x	x	
Endothall	EPA 548.1	x	x	
Enterococci	SM 9230B	x		x
Fecal Coliform	SM 9221 E (MTF/EC)	x		
Fecal Coliform	SM 9221C, E (MTF/EC)			x
Fecal Coliform (Enumeration)	SM 9221E (MTF/EC)	x	x	
Fecal Coliform with Chlorine Present	SM 9221E			x
Fecal Streptococci	SM 9230B	x		x
Fluoride	SM 4500-F C	x	x	x
Glyphosate	EPA 547	x	x	
Gross Alpha/Beta	EPA 900.0	x	x	x
HAAs/ Dalapon	EPA 552.3	x	x	
Hardness	SM 2340B	x	x	x
Heterotrophic Bacteria	In House Method	x	x	
Heterotrophic Bacteria	SM 9215 B	x	x	
Hexavalent Chromium	EPA 218.6	x	x	x
Hexavalent Chromium	EPA 218.7	x	x	
Hexavalent Chromium	SM 3500-Cr B or C (20th)			x

SPECIFIC TESTS	METHOD OR TECHNIQUE USED	Drinking Water	Food & Beverage	Waste Water
Hormones	EPA 539	x	x	
Hydroxide as OH Calc.	SM 2330B	x	x	
Kjeldahl Nitrogen	EPA 351.2			x
Mercury	EPA 245.1	x	x	x
Metals	EPA 200.7 / 200.8	x	x	x
Microcystin LR	ELISA	x	x	
NDMA	EPA 521	x	x	
Nitrate/Nitrite Nitrogen	EPA 353.2	x	x	x
OCL, Pesticides/PCB	EPA 505	x	x	
Ortho Phosphate	EPA 365.1	x	x	
Ortho Phosphate and Total Phosphorous	EPA 365.1/SM 4500-P E			x
Ortho Phosphorous	SM 4500P E	x	x	
Oxyhalides Disinfection Byproducts	EPA 317.0	x	x	
Perchlorate	EPA 331.0	x	x	
Perchlorate	EPA 314.0	x	x	
Perfluorinated Alkyl Acids	EPA 537	x	x	
pH	EPA 150.1	x		
pH	SM 4500-H+B	x	x	x
Phenylurea Pesticides/Herbicides	In House Method	x	x	
Pseudomonas	IDEXX Pseudalert	x	x	
Radium-226	RA-226 GA	x	x	
Radium-228	RA-228 GA	x	x	
Radon-222	SM 7500RN	x	x	
Residue, Filterable	SM 2540C	x	x	x
Residue, Non-filterable	SM 2540D			x
Residue, Total	SM 2540B		x	x
Residue, Volatile	EPA 160.4			x
Semi-VOC	EPA 525.2	x	x	
Semi-VOC	EPA 625	x	x	x
Silica	SM 4500-Si D	x	x	x
Silica	SM 4500-SiO2 C	x		x
Sulfide	SM 4500-S ²⁻ D			x
Sulfite	SM 4500-SO ³⁻ B	x	x	x
Surfactants	SM 5540C	x	x	x
Taste and Odor Analytes	SM 6040E	x	x	
Total Coliform	SM 9221 A, B	x	x	
Total Coliform (Enumeration)	SM 9221 A, B, C	x	x	
Total Coliform / E. coli	Colisure	x	x	
Total Coliform	SM 9221B			x
Total Coliform with Chlorine Present	SM 9221B			x
Total Coliform / E.coli	SM 9223	x	x	
TOC	SM 5310C		x	x
TOC/DOC	SM 5310C	x	x	
TOX	SM 5320B			x
Total Phenols	EPA 420.1			x
Total Phenols	EPA 420.4	x	x	x
Total Phosphorous	SM 4500 P F			x
Turbidity	EPA 180.1	x	x	x
Turbidity	SM 2130B	x		x
Uranium by ICP/MS	EPA 200.8	x	x	
UV 254	SM 5910B	x		
VOC	EPA 524.2/EPA 524.3	x	x	
VOC	EPA 624	x	x	x
VOC	EPA SW 846 8260	x	x	
VOC	In House Method	x	x	
Yeast and Mold	SM 9610	x	x	

The following samples were received from you on **June 03, 2014**. They have been scheduled for the tests listed below each sample. If this information is incorrect, please contact your service representative. Thank you for using Eurofins Eaton Analytical.

Sample #	Sample ID	Sample Date
201406030532	Alkapuro product BEST BY 05/09/16 1000ML	06/03/2014 1346
	@2378-TCDD_Dioxin @505 @515.4	
	@525 @531 @549	
	@551SODA @900 @ANIONS28	
	@ANIONS48 @COLI10 @DBP_14	
	@HAA @ICP @ICPMS	
	@VOA Apparent Color Bromate by UV/VIS	
	Chloramines Chlorine Dioxide Cyanide	
	Endothall Fluoride Free Chlorine Residual	
	Glyphosate Mercury Odor at 60 C (TON)	
	PH, Bottled Water Phenolic Compounds-low level Total Chlorine Residual	
	Total Dissolved Solid (TDS) Turbidity @RA226 GA	
	@RA228 GA	

Test Description

- @2378-TCDD_Dioxin -- 2,3,7,8-TCDD_Dioxin
- @505 -- Organochlorine Pesticides/PCBs
- @515.4 -- Chlorophenoxy Herbicides
- @525 -- Semivolatiles by GCMS
- @531 -- Aldicarb
- @549 -- Diquat and Paraquat
- @551SODA -- EDB/DBCP/HAN by EPA 551.1
- @900 -- Gross Alpha/Beta Radiation
- @ANIONS28 -- Chloride, Sulfate by EPA 300.0
- @ANIONS48 -- Nitrate, Nitrite by EPA 300.0
- @COLI10 -- Total & Fecal Coliform, 24 Hour
- @DBP_14 -- Chlorite by 300.0
- @HAA -- Haloacetic Acids
- @ICP -- ICP Metals
- @ICPMS -- ICPMS Metals
- @VOA -- Volatile Organics by GCMS
- @RA226 GA -- Radium 226

Acknowledgement of Samples Received

Addr: **Alkapuro inc**
7125 Telegraph Rd
Montebello, CA 90640

Attn: Randy Park
Phone: 714-883-9115

Client ID: ALKAPURO
Folder #: 484133
Project: BW
Sample Group: FDA Product

Project Manager: Andrew.D.Eaton
Phone: (626) 386-1125
PO #: Prepay

The following samples were received from you on **June 03, 2014**. They have been scheduled for the tests listed below each sample. If this information is incorrect, please contact your service representative. Thank you for using Eurofins Eaton Analytical.

Sample #	Sample ID	Sample Date
	@RA228 GA -- Radium 228	

750 Royal Oaks Drive, Suite 100
Monrovia, California 91016-3629
Tel: (626) 386-1100
Fax: (626) 386-1101
1 800 566 LABS (1 800 566 5227)

Client: Alkapuro inc
7125 Telegraph Rd
Montebello, CA 90640

Attention: Randy Park

Sample Id: Alkapuro product BEST BY 05/09/16 1000ML
Date Sampled: 6/3/2014

Investigation: Analysis per Title 21, Federal Code of Regulations 103.35 - California Limits

Laboratory FDA_CA
Report: 484133

Report Date: 07/07/2014
Date Received: 06/03/2014
Sample No: 201406030532

ANALYTICAL RESULTS

Parameter	Method	Reporting Limit	Result	SOQ
GROUP I				
PHYSICAL				
Apparent Color	SM 2120B	3.0	ND ACU	15
Odor at 60 C (TON)	SM 2150B	1.0	ND TON	3
pH	SM 4500 HB	0.10	10	no std
Total Dissolved Solid (TDS)	SM 2540C	10	44	500
Turbidity	EPA 180.1	0.050	0.31 NTU	5
GROUP II				
CHEMICAL SUBSTANCE 1				
		Milligrams per Liter		
Aluminum Total ICAP/MS	EPA 200.8	0.020	0.099	0.2
Antimony Total ICAP/MS	EPA 200.8	0.0010	ND	0.006
Arsenic Total ICAP/MS	EPA 200.8	0.0010	ND	0.010
Barium Total ICAP/MS	EPA 200.8	0.0020	ND	2
Beryllium Total ICAP/MS	EPA 200.8	0.0010	ND	0.004
Cadmium Total ICAP/MS	EPA 200.8	0.00050	ND	0.005
Chloride	EPA 300.0	1.0	1.9	250
Chromium Total ICAP/MS	EPA 200.8	0.0010	ND	0.1
Copper Total ICAP/MS	EPA 200.8	0.0020	ND	1.0
Cyanide	SM 4500CN-F	0.025	ND	0.2
Fluoride	SM 4500F-C	0.050	ND	1.4
Iron Total ICAP	EPA 200.7	0.020	ND	0.3
Lead Total ICAP/MS	EPA 200.8	0.00050	ND	0.005
Manganese Total ICAP/MS	EPA 200.8	0.0020	ND	0.05
Mercury	EPA 245.1	0.00020	ND	0.002
Nickel Total ICAP/MS	EPA 200.8	0.0050	ND	0.1
Nitrate-N	EPA 300.0	0.10	0.16	10
Nitrite-N	EPA 300.0	0.050	ND	1
Phenol	EPA 420.4	0.0010	ND	0.001
Selenium Total ICAP/MS	EPA 200.8	0.0050	ND	0.05

SOQ=Standard of Quality per FDA or California
ND=Not detected at the specified limit
All results reported in milligrams per liter unless otherwise noted

Parameter	Method	Reporting Limit	Result	SOQ
Silver Total ICAP/MS	EPA 200.8	0.00050	ND	0.1
Sulfate	EPA 300.0	0.50	ND	250
Thallium Total ICAP/MS	EPA 200.8	0.0010	ND	0.002
Total Nitrate + Nitrite	EPA 300.0	0.10	0.16	10
Zinc Total ICAP/MS	EPA 200.8	0.020	ND	5.0
GROUP III CHEMICAL SUBSTANCE 2 (VOC)		Milligrams per Liter		
1,1,1,2-Tetrachloroethane	EPA 524.2	0.00050	ND	no std
1,1,1-Trichloroethane	EPA 524.2	0.00050	ND	0.20
1,1,2,2-Tetrachloroethane	EPA 524.2	0.00050	ND	no std
1,1,2-Trichloroethane	EPA 524.2	0.00050	ND	0.005
1,1-Dichloroethane	EPA 524.2	0.00050	ND	no std
1,1-Dichloroethene	EPA 524.2	0.00050	ND	0.007
1,1-Dichloropropene	EPA 524.2	0.00050	ND	no std
1,2,3-Trichlorobenzene	EPA 524.2	0.00050	ND	no std
1,2,3-Trichloropropane	EPA 524.2	0.00050	ND	no std
1,2,4-Trichlorobenzene	EPA 524.2	0.00050	ND	0.07
1,2,4-Trimethylbenzene	EPA 524.2	0.00050	ND	no std
1,2-Dichloroethane	EPA 524.2	0.00050	ND	0.005
1,2-Dichloropropane	EPA 524.2	0.00050	ND	0.005
1,3,5-Trimethylbenzene	EPA 524.2	0.00050	ND	no std
1,3-Dichloropropane	EPA 524.2	0.00050	ND	no std
2,2-Dichloropropane	EPA 524.2	0.00050	ND	no std
Benzene	EPA 524.2	0.00050	ND	0.005
Bromobenzene	EPA 524.2	0.00050	ND	no std
Bromochloromethane	EPA 524.2	0.00050	ND	no std
Bromodichloromethane	EPA 524.2	0.00050	ND	no std
Bromoform	EPA 524.2	0.00050	ND	no std
Bromomethane	EPA 524.2	0.00050	ND	no std
Carbon Tetrachloride	EPA 524.2	0.00050	ND	0.005
Chlorobenzene	EPA 524.2	0.00050	ND	0.1
Chlorodibromomethane	EPA 524.2	0.00050	ND	no std
Chloroethane	EPA 524.2	0.00050	ND	no std
Chloroform (Trichloromethane)	EPA 524.2	0.00050	ND	no std
Chloromethane	EPA 524.2	0.00050	ND	no std
cis-1,2-Dichloroethylene	EPA 524.2	0.00050	ND	0.07
cis-1,3-Dichloropropene	EPA 524.2	0.00050	ND	no std
Dibromomethane	EPA 524.2	0.00050	ND	no std

SOQ=Standard of Quality per FDA or California
ND=Not detected at the specified limit
All results reported in milligrams per liter unless otherwise noted

Parameter	Method	Reporting Limit	Result	SOQ
Dichlorodifluoromethane	EPA 524.2	0.00050	ND	no std
Dichloromethane	EPA 524.2	0.00050	ND	0.005
Ethyl benzene	EPA 524.2	0.00050	ND	0.7
Fluorotrichloromethane-Freon11	EPA 524.2	0.00050	ND	no std
Hexachlorobutadiene	EPA 524.2	0.00050	ND	no std
Isopropylbenzene	EPA 524.2	0.00050	ND	no std
m,p-Xylenes	EPA 524.2	0.00050	ND	no std
m-Dichlorobenzene (1,3-DCB)	EPA 524.2	0.00050	ND	no std
MTBE	EPA 524.2	0.00050	ND	no std
n-Butylbenzene	EPA 524.2	0.00050	ND	no std
n-Propylbenzene	EPA 524.2	0.00050	ND	no std
o-Chlorotoluene	EPA 524.2	0.00050	ND	no std
o-Dichlorobenzene (1,2-DCB)	EPA 524.2	0.00050	ND	0.6
o-Xylene	EPA 524.2	0.00050	ND	no std
p-Chlorotoluene	EPA 524.2	0.00050	ND	no std
p-Dichlorobenzene (1,4-DCB)	EPA 524.2	0.00050	ND	0.075
p-Isopropyltoluene	EPA 524.2	0.00050	ND	no std
sec-Butylbenzene	EPA 524.2	0.00050	ND	no std
Styrene	EPA 524.2	0.00050	ND	0.1
tert-Butylbenzene	EPA 524.2	0.00050	ND	no std
Tetrachloroethylene (PCE)	EPA 524.2	0.00050	ND	0.005
Toluene	EPA 524.2	0.00050	ND	1
Total 1,3-Dichloropropene	EPA 524.2	0.00050	ND	0.0005
Total THM	EPA 524.2	0.00050	ND	0.010
Total xylenes	EPA 524.2	0.00050	ND	10
trans-1,2-Dichloroethylene	EPA 524.2	0.00050	ND	0.1
trans-1,3-Dichloropropene	EPA 524.2	0.00050	ND	no std
Trichloroethylene (TCE)	EPA 524.2	0.00050	ND	0.005
Trichlorotrifluoroethane(Freon	EPA 524.2	0.00050	ND	no std
Vinyl chloride (VC)	EPA 524.2	0.00030	ND	0.002
GROUP IV CHEMICAL SUBSTANCE 3 (NON VOC)		Milligrams per Liter		
2,3,7,8-TCDD, ug/L	EPA 1613B	0.000000050	ND	0.000030
2,4,5-TP (Silvex)	EPA 515.4	0.00020	ND	0.05
2,4-D	EPA 515.4	0.00010	ND	0.07
3-Hydroxycarbofuran	EPA 531.2	0.00050	ND	no std
Alachlor (Alanex)	EPA 505	0.00010	ND	0.002
Aldicarb (Temik)	EPA 531.2	0.00050	ND	no std

SOQ=Standard of Quality per FDA or California
ND=Not detected at the specified limit
All results reported in milligrams per liter unless otherwise noted

750 Royal Oaks Drive, Suite 100
Monrovia, California 91016-3629
Tel: (626) 386-1100
Fax: (626) 386-1101
1 800 566 LABS (1 800 566 5227)

Report Date: 07/07/2014
Date Received: 06/03/2014
Sample No: 201406030532

Parameter	Method	Reporting Limit	Result	SOQ
Aldicarb sulfone	EPA 531.2	0.00050	ND	no std
Aldicarb sulfoxide	EPA 531.2	0.00050	ND	no std
Atrazine	EPA 525.2	0.000050	ND	0.003
Baygon	EPA 531.2	0.00050	ND	no std
Bentazon	EPA 515.4	0.00050	ND	0.018
Benzo(a)pyrene	EPA 525.2	0.000020	ND	0.0002
Carbaryl	EPA 531.2	0.00050	ND	no std
Carbofuran	EPA 531.2	0.00050	ND	40
Chlordane	EPA 505	0.00010	ND	0.002
Dalapon	EPA 515.4	0.0010	ND	0.2
Di-(2-Ethylhexyl)adipate	EPA 525.2	0.00060	ND	0.4
Di(2-Ethylhexyl)phthalate	EPA 525.2	0.00060	ND	0.004
Dibromochloropropane (DBCP)	EPA 551.1	0.000010	ND	0.0002
Dinoseb	EPA 515.4	0.00020	ND	0.007
Diquat	EPA 549.2	0.00040	ND	0.02
Endothall	EPA 548.1	0.0050	ND	0.1
Endrin	EPA 505	0.000010	ND	0.002
Ethylene Dibromide (EDB)	EPA 551.1	0.000010	ND	0.00005
Glyphosate	EPA 547	0.0060	ND	0.7
Heptachlor	EPA 505	0.000010	ND	0.0004
Heptachlor Epoxide	EPA 505	0.000010	ND	0.0002
Hexachlorobenzene	EPA 525.2	0.000050	ND	0.001
Hexachlorocyclopentadiene	EPA 525.2	0.000050	ND	0.05
Lindane (gamma-BHC)	EPA 505	0.000010	ND	0.0002
Methiocarb	EPA 531.2	0.00050	ND	no std
Methomyl	EPA 531.2	0.00050	ND	no std
Methoxychlor	EPA 505	0.000050	ND	0.04
Oxamyl (Vydate)	EPA 531.2	0.00050	ND	0.2
Pentachlorophenol	EPA 515.4	0.000040	ND	0.001
Picloram	EPA 515.4	0.00010	ND	0.5
Simazine	EPA 525.2	0.000050	ND	0.004
Thiobencarb	EPA 525.2	0.00020	ND	no std
Total PCBs	EPA 505	0.00010	ND	0.5
Toxaphene	EPA 505	0.00050	ND	0.003
GROUP V				
RADIOACTIVITY		Picocuries per Liter		
Alpha, Gross	EPA 900.0	3.0	ND	15
Beta, Gross	EPA 900.0	3.0	ND	50

SOQ=Standard of Quality per FDA or California
ND=Not detected at the specified limit
All results reported in milligrams per liter unless otherwise noted

750 Royal Oaks Drive, Suite 100
Monrovia, California 91016-3629
Tel: (626) 386-1100
Fax: (626) 386-1101
1 800 566 LABS (1 800 566 5227)

Report Date: 07/07/2014
Date Received: 06/03/2014
Sample No: 201406030532

Parameter	Method	Reporting Limit	Result	SOQ
Radium 226	Ra-226 GA	1.0	ND	3
Radium 228	Ra-228 GA	1.0	ND	5
Uranium ICAP/MS (mg/L)	EPA 200.8	0.0010	ND	0.03
GROUP VIa				
BACTERIOLOGICAL		Colonies/100 mL		
E. Coli Bacteria	SM 9223	1.1	<1.1	1.1
Total Coliform Bacteria	SM 9223	1.1	<1.1	2.2
GROUP VII				
Disinfection Byproducts		Milligrams per Liter		
Bromate by UV/VIS	EPA 317	0.0010	ND	0.01
Chlorite	EPA 300.0	0.010	ND	1
D/DBP Haloacetic Acids (HAA5)	SM 6251B	0.0020	ND	0.06
GROUP VIII				
Residual Disinfectants		Milligrams per Liter		
Chloramines	SM 4500CL-G/HACH	0.10	ND	4
Chlorine Dioxide	SM 4500CLO2-D/HACH	0.24	ND	0.8
Total Chlorine Residual	SM 4500CL-G/HACH	0.10	ND	4

SOQ=Standard of Quality per FDA or California
ND=Not detected at the specified limit
All results reported in milligrams per liter unless otherwise noted

750 Royal Oaks Drive, Suite 100
 Monrovia, California 91016-3629
 Tel: (626) 386-1100
 Fax: (626) 386-1101
 1 800 566 LABS (1 800 566 5227)

Laboratory Hits
 Report: 484133

Generosity Beverages Inc.
 12800 Riverside Dr. Suite 200
 Valley Village, CA 91607
 Attn: Micah Cravalho

Samples Received on:
 06/03/2014

Analyzed	Analyte	Sample ID	Result	Federal MCL	Units	MRL
201406030532 Generosity Beverages Product BEST BY 05/09/16 1000ML						
06/23/2014 12:23	Aluminum Total ICAP/MS		99	200	ug/L	20
06/04/2014 16:17	Chloride		1.9	250	mg/L	1
06/04/2014 16:17	Nitrate as Nitrogen by IC		0.16	10	mg/L	0.1
06/04/2014 16:17	Nitrate as NO3 (calc)		0.72	45	mg/L	0.44
06/10/2014 14:00	PH Bottled Water		10		Units	0.1
06/10/2014 15:12	Total Dissolved Solids (TDS)		44	500	mg/L	10
06/04/2014 16:17	Total Nitrate, Nitrite-N, CALC		0.16		mg/L	0.1
06/04/2014 16:13	Turbidity		0.31	5	NTU	0.05